



CB TEST CERTIFICATE

Ref. Certificate No.

NL-21476/A1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by: DEKRA Certification B.V.

Product: Residual current circuit breaker

Applicant: HYUNDAI HEAVY INDUSTRIES CO., LTD. 1, JEONHA-DONG, DONG-GU, ULSAN Korea, Republic of

Manufacturer: HYUNDAI HEAVY INDUSTRIES CO., LTD. 1, JEONHA-DONG, DONG-GU, ULSAN Korea, Republic of

Factory: HYUNDAI HEAVY INDUSTRIES(CHINA) ELECTRIC CO., LTD. No. 9 Hyundai Road, Xinba Scientific and Technologic Zone, Yangzhong, Jiangsu China

Rating and principal characteristics: $U_n = 240 \text{ Vac (2P)}, 415 \text{ Vac (4P)}$
 $I_n = 16, 25, 32, 40, 50, 63, 80, 100 \text{ A}$
 $I_{\Delta n} = 30, 100, 300 \text{ mA (A-type)}$ 30, 100, 300, 500 mA(AC-type)
 $I_{nc} = I_{\Delta c} = 6 \text{ kA}$
 $I_m = I_{\Delta m} = 10 I_n \text{ or } 500 \text{ A}$ which ever is greater
 A and AC type
 Without time delay

Trade mark (if any): HYUNDAI

Model/Type reference: HiRC63 , HiRC100

Additional information: A1: editorial corrections

Sample of product tested to be in conformity with IEC: 61008-1(ed.3)

Test Report Ref. No: 3301901.50

This CB Test Certificate is issued by the National Certification Body:


DEKRA Certification B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands



DEKRA Certification is
former KEMA Quality

Signed by: F.S.Strikwerda

Date of issue: 2011-09-22



CB TEST CERTIFICATE

Ref. Certificate No.

NL-21476/A1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by: DEKRA Certification B.V.

Product: Residual current circuit breaker

Applicant: HYUNDAI HEAVY INDUSTRIES CO., LTD. 1, JEONHA-DONG, DONG-GU, ULSAN Korea, Republic of

Manufacturer: HYUNDAI HEAVY INDUSTRIES CO., LTD. 1, JEONHA-DONG, DONG-GU, ULSAN Korea, Republic of

Factory: HYUNDAI HEAVY INDUSTRIES(CHINA) ELECTRIC CO., LTD. No. 9 Hyundai Road, Xinba Scientific and Technologic Zone, Yangzhong, Jiangsu China

Rating and principal characteristics: $U_n = 240 \text{ Vac (2P)}, 415 \text{ Vac (4P)}$
 $I_n = 16, 25, 32, 40, 50, 63, 80, 100 \text{ A}$
 $I_{\Delta n} = 30, 100, 300 \text{ mA (A-type)}$ 30, 100, 300, 500 mA(AC-type)
 $I_{nc} = I_{\Delta c} = 6 \text{ kA}$
 $I_m = I_{\Delta m} = 10 I_n \text{ or } 500 \text{ A}$ which ever is greater
 A and AC type
 Without time delay

Trade mark (if any): HYUNDAI

Model/Type reference: HiRC63 , HiRC100

Additional information: A1: editorial corrections

Sample of product tested to be in conformity with IEC: 61008-1(ed.3)

Test Report Ref. No: 3301901.50

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands



DEKRA Certification is
former KEMA Quality

Signed by: F.S.Strikwerda

Date of issue: 2011-09-22