

## CERTIFICATE OF CONFORMITY

### According to LVD Directive 2006/95/EC

This certificate is only valid for products submitted to Underwriters Laboratories for certifications, which are identical

Certificate No.	E205705-12-01
Product	Inverter Drive
Model /Type ref.	N700E-004LF, N700E-007LF, N700E-015LF, N700E-022LF, N700E-037LF, N700E-004SF, N700E-007SF, N700E-015SF, N700E-022SF, N700E-004HF, N700E-007HF, N700E-015HF, N700E-022HF, N700E-037HF
Holder of Certificate	HYUNDAI HEAVY INDUSTRIES CO LTD 1, CHEON HA-DONG, DONG-GU, ULSAN, KYUNGNAM, 682-060, KOREA
Manufacturer	ADT CO LTD 984-3 GWANYANG-DONG, DONGAN-GU, ANYANG-SI, GYEONGGI-DO, 431-060 KOREA
Trade Mark	 <b>HYUNDAI</b> or <b>HYUNDAI</b>
Electrical Rating	See appendix
Insulation Class	Class I
Degree of Protection	IP20
Additional Information	None

This certificate is only valid for products submitted to Underwriters Laboratories for certificate, which are identical to the tested and certified product(s) . It is confirmed that a sample of the product has been tested and found in conformity with the following standard(s):

Standard(s): EN61800\_5\_1A

Detailed specification of the tested and certified product are shown in the following Test Report:

Test Report Ref. No. : 12CA07777-CE      Issued Date: 2012-03-27      By: UL Korea Ltd.

The Member States of the EU shall presume compliance with the provisions of the Low Voltage Directive (LVD) 2006/95/EC of 27<sup>th</sup> December, 2006, when the product is carrying the CE-mark of conformity, a Declaration of Conformity with the LVD Directive has been completed and signed by the manufacturer or his authorized representative established within the Community, and when the additional requirements of Annex IV regarding internal production control and the presence of technical documentation are complied with.

This document contains 1 page(s).

Date : 2012-04-05



Signature.....

**SooKil Park**  
Engineering Manager  
Conformity Assessment Services

**UL Korea Ltd.**  
33<sup>rd</sup> Fl. Gangnam Finance Center, 737  
Yeoksam-dong, Gangnam-gu, Seoul, Korea  
Tel:+82 2 2009 9000 Fax:+82 2 2009 9404

## Appendix to CE LVD Certificate No. E205705-12-01

The certificate covers the following :

Electrical Rating: Model	INPUT			OUTPUT			
	Vac	Current (A)	Phase	Vac	Phase	Frequency (Hz)	FLA (A)
N700E-004LF	200-240	4.0	3	0 - Vin	3	0.1 - 400	3.0
N700E-007LF	200-240	6.5	3	0 - Vin	3	0.1 - 400	5.0
N700E-015LF	200-240	10.0	3	0 - Vin	3	0.1 - 400	7.0
N700E-022LF	200-240	15.0	3	0 - Vin	3	0.1 - 400	11.0
N700E-037LF	200-240	24.0	3	0 - Vin	3	0.1 - 400	17.0
N700E-004SF	200-240	6.0	1	0 - Vin	3	0.1 - 400	3.0
N700E-007SF	200-240	8.3	1	0 - Vin	3	0.1 - 400	5.0
N700E-015SF	200-240	15.0	1	0 - Vin	3	0.1 - 400	7.0
N700E-022SF	200-240	18.0	1	0 - Vin	3	0.1 - 400	11.0
N700E-004HF	380-480	2.2	3	0 - Vin	3	0.1 - 400	1.8
N700E-007HF	380-480	4.0	3	0 - Vin	3	0.1 - 400	3.4
N700E-015HF	380-480	5.2	3	0 - Vin	3	0.1 - 400	4.8
N700E-022HF	380-480	8.5	3	0 - Vin	3	0.1 - 400	7.2
N700E-037HF	380-480	12.0	3	0 - Vin	3	0.1 - 400	9.2

Date : 2012-04-05

Signature.....



**Sookil Park**  
Engineering Manager  
Conformity Assessment Services

**UL Korea Ltd.**  
33<sup>rd</sup> Fl. Gangnam Finance Center, 737  
Yeoksam-dong, Gangnam-gu, Seoul, Korea  
Tel:+82 2 2009 9000 Fax:+82 2 2009 9404

